



Nº referencia: 33/X42/1/6111395-3 rev.1

REPORT: DRAVES TEST FOR FOAM AGENT BOLDFOAM F-40 100% ACCORDING TO STANDARD ASTM D2281-68 AT 25°C.

Laura Fuego San Francisco, ECA GRUPO BUREAU VERITAS, Inspector in Llanera.

Attests,

That on request of VS FOCUM S.L. has witnessed on November 26 th, 2012 at its premises located in Porceyo (Gijón. Asturias), tests corresponding to the standard ASTM D2281-68, for BoldFoam F-40 (Batch: F40111201/ Manufacturing date 11/2012),

CONCLUSIONS: According to Standard ASTM D2281-68, 4 draves tests have been carried out on the solution for 100% concentration and 25°C temperature, and the following results have been obtained.

DRAVES TEST	
BoldFoam F-40 (100%)	
ENSAYOS	TIEMPO (s)
1	1"
2	1"
3	1"
4	1"

In witness where of, I hereby sign this report in Llanera on November 26th, 2012

Signed: Laura Fuego San Francisco

